

Annexure C

PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No. JAM/DLWT/MDB/115

Dated: 31/01/2026

It is certified that an inspection team headed by Raman Kumar, Jt. In-Asst.

(Name of Officers with designation) from District Level Water Testing PHED

Inspected the J.S. Public School HISSAR

(Name & Address of the school) on 29.01.2026 (date of inspection) and on the basis of

Water Test Report (Attached) bearing no. JAM/DLWT/MDB/115 dated 31.01.2026

at DLWT Madhubani (PHED Lab) certified that the

J.S. Public School HISSAR (Name of school) has safe drinking water

facilities for the students and members of staff of the institution. School is also maintains the

hygienic sanitation condition in the school building & the campus as per norms prescribed by the

Central/ State/ U.T. Govt.

This certificate is valid till 6 months (Provisional & Post revision) from the date of

Signature with Seal: [Signature]

Name: Ashok Dargan

Designation: PHED

Name & Address of the Office / Department: DLWT

Lab Madhubani

PHED MIST

P.B.D. Madhubani

To J.S. Public School HISSAR

(Name & Address of the Institution)

Note: The certificate is to be issued by authorized officer / PHED Lab / local bodies

DISTRICT LEVEL WATER TESTING LABORATORY P.H.DIVISION, MADHUBANI

Letter No- 13 (Lab)
Dated- 31.01.2026

Sampling Date:- 29/01/2026
Testing Date:- 31/01/2026
Months:- JANUARY, 2026

Sample Collected & Submitted by Lab.Staff.

Sl No	Block	Panchayat	Village/Town	Source of Water	Name of Location/ Nearest Person	PH.	Tub.	T.H	T.A	Ca	Mg	Cl	Fe	F	TDS	EC	BACTERIA	Remarks
1	Harlakhi	Hissar	Hissar	R.O	IS PUBLIC SCHOOL HISSAR.	7.3	3.2	200	280	28	9	30	0.3	0.2	176	258	A	
Min-Max-Permissible Limit						6.5 - 8.5	1.0-05	200 - 600	200 - 600	75 - 200	30 - 100	250 - 1000	1.0	0.5-15	500 - 2000		Absent/Present	

*BDL- Below Detection Limit

*A - Absent

NOTE:- THIS TEST REPORT IS VALID FOR ONLY 06 MONTHS (Pre-monsoon & Post-monsoon) FROM THE DATE OF TESTING

(Signature)
31/01/2026

Lab Assistant

District Level Laboratory, Madhubani

(Signature)
31/01/2026

Chemist

District Level Laboratory, Madhubani

PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No. : 28

Dated: 20/02/2026

It is certified that an inspection team headed by Dr. Vijay Kumar (MO)

(Name of Officers with designation) from CHC Harlakhi (PHED) CHC

Inspected the I S PUBLIC SCHOOL at V.P.O. - Hissar, VIA + P.S. - Khirhar, Block - Harlakhi, Madhubani,

Bihar - 847230 on 20/02/2026 (date of inspection) and on the basis of Water Test

Report (Attached) bearing No. 13 dated 31/01/26 of Madhubani (PHED Lab)

certified that the I S PUBLIC SCHOOL at V.P.O. - Hissar, VIA + P.S. - Khirhar, Block - Harlakhi,

Madhubani, Bihar has safe drinking water facilities for the students and members of staff of the

institution. School is also maintaining the hygienic sanitation condition in the school building and the

campus as per norms prescribed by the Central / State / U.T. Government.

This certificate is valid till 19/02/2029 i.e Three years

Signature with seal: [Signature]

Name : Dr. Vijay Kumar

Designation : MO CHC Harlakhi

Name & address of the Office / Department :

डा० विजय कुमार
चिकित्सा पदाधिकारी
सामुदायिक स्वास्थ्य केन्द्र,
हरलाखी, मधुबनी
फ़ोन नं०-50270/20

To

I S PUBLIC SCHOOL

V.P.O. - Hissar, VIA + P.S. - Khirhar, Block - Harlakhi, Madhubani, Bihar - 847230